

DICHIARAZIONE DI CONFORMITA'
DECLARATION OF CONFORMITY

N° 1STC 860054


ABB S.p.A. – ABB SACE Division, developer and system owner of the ArTu K low voltage switchgear systems, confirms that the maximum distance between two busbars holder BP3200 using N°3 busbars per phase, In=4000A and Icw=85kA, is 400mm

Garbagnate Monastero, LC Italy 26-05-2016



Roberto Galuppi

Global Product Group Manager
Power Enclosures



Andrea Tagliabue

R&D Manager
Power Enclosures



Prepared by Piercelesté Benedetti

R&D Department
Power Enclosures

ABB SpA

Sede legale
Registered Office
Via Vittor Pisani, 16
20124 Milano - Italy
www.abb.it

Direzione e
Uffici Amministrativi
Headquarters and
Accounting Services
20099 Sesto S. Giovanni (MI) - Italy
Via Luciano Lama, 33
Tel.: +39 02 2414.1

Capitale Sociale
Share Capital
€ 110.000.000 i.v./fully paid up
P.IVA/VAT: IT 11988960156
Codice Fiscale/Fiscal code: 00736410150
Registro delle imprese di Milano/
Official Company Book: 00736410150
R.E.A. Milano: 1513225

ABB SACE Division

Unità Produttive/Factories
Bergamo
Dalmine (BG)
Frosinone
Garbagnate Monastero (LC)
Marostica (VI)
San Martino in Strada (LO)
Santa Palomba (Roma)
Vittuone (MI)